

Declaration of Performance – 5037-DWN

1. **Drywall nails** of the following diameter:

2.65 mm

2. Batch numbered labels are attached to box or pack to allow batch identification
 3. **Drywall nails** are designed as mechanical fasteners for gypsum plasterboard systems.
 4. Manufacturer:

**Hexstone Limited t/as Owlett-Jaton,
 Opal Way, Stone, Staffordshire, ST15 0SW
 Factory number 474**

5. Tested to EN 14566+A1:2009 under system 4 by

**SHR, "Het Cambium", Nieuwe Kanaal 9b, P.O. Box 497
 6700 AL Wageningen, The Netherlands**

Test date 19th March 2014

6. Declared Performance for the drywall nails conforming to EN 14566+A1:2009

	Criteria	2.65 mm
Length	L+/- 2 mm	Pass
Head Diameter	7.8mm +/- 0.3 mm	Pass
Withdrawal Force	200N min	Pass
Tested in Spruce 450 kg/m ³ WMC 13%, driven to depth of 20mm		
Bending Behaviour	90° without crack	Pass
Material used for production	C10D produced in accordance with EN 10016-1 to -4	
Class of corrosion protection	48 Hour – no visible rusting	Pass
Reaction to fire	No contribution to fire	

7. The performance of the mentioned products is in conformity with the declared performance given. This declaration of performance is issued under the sole responsibility of the manufacturer.

Signed for and on behalf of the manufacturer by:

John Barker Purchasing Director Owlett-Jaton

Signature: *J. Barker*

Date: *20th April 2014*